

C# 183852
S# 205287
I# 12704

VILLAGE OF FOX POINT

7200 N. SANTA MONICA BLVD.
FOX POINT 53217
414-351-8900

OFFICE USE ONLY

Permit No. 18654
Received 6/12/07
Service
Rough-In
Final

APPLICATION FOR ELECTRICAL PERMIT

Date _____
License No. 979322

PLEASE TYPE OR PRINT WITH BALL POINT PEN

Builder _____ Owner Kathleen/Brian Hanson Occupant Kathleen/Brian Hanson
Job Address 8401 N. Fox Craft Lane

ESTIMATED COST OF JOB

- Buildings ☒ Residential
☐ Commercial
☐ Industrial
☐ Institutional
☐ New Construction
☐ Additional Rooms
☐ Remodeling
☐ New Occupancy

Where on Premises?

Describe Rear of Home

List Name of Installing Contractor

HEATING

AIR CONDITIONING Blaw Heating

PLUMBING

Date of Inspection

Rough _____ Will Call ☐
Final _____ Will Call ☐
Service Approval Sent _____ ☐

REMARKS:

No.	Description	Qty.	Rate of Fees	Dollars	Cents
1	Light, switch and convenience outlets		.35 ea		
2	Lighting Fixtures		.30 ea		
3	Fluorescent Fixtures - per tube		.30 ea		
4	Range, Electric		4.00 ea		
5	Garbage Grinding and Disposal Unit		3.00 ea		
6	Dishwasher		4.00 ea		
7	Clothes Dryer		4.00 ea		
8	Water Heaters, Electric		4.00 ea		
9	Gas Burner, Oil Burner or Stoker		5.00 ea		
10	Refrigerating, Air Cooling or similar machine - .25 per HP	2	5.00 min	10.00	
11	Feeders - No. 6 A.W.G. or Larger		7.00 ea		
12	Temporary Service Permit for: How Long?		10.00 ea		
13	Services: Service Switches, ea.		5.00 ea		
	Service 1. 0 through 100 amps.		5.00 ea		
	2. 101 through 400 amps.		10.00 ea		
	3. 401 through 600 amps.		10.00 ea		
	4. 601 through 1000 amps.		15.00 ea		
	5. Thereafter, ea. additional 1000 amps.		5.00 ea		
14	Motors over 1/4 HP		.30 per HP or frac		
15	Fuel Dispensing Pumps		6.00 ea		
16	Transformers, Rectifiers and Generators		.30 per KW		
17	Space Heating Systems, per circuit		3.00 ea		
18	Power receptacles - 120 Volts or over 1. Through 30 amps		3.00 ea		
19	2. Over 30 amps		5.00 ea		
20	Wireways, busways, underfloor raceways or auxiliary gutters		.25 per ft		
21	Strip Lighting, Plug-in Strip, Trol-E Duct or similar system		.20 per ft		
22	Signs, Electric - .10 ea. socket, plus .50 ea. add'l. transformer		8.00 min		
23	Swimming Pool Wiring: A. Inground pools		40.00		
24	B. Above ground pools		25.00		
25	Spas, Hot-tubs, Hydromassage Bathtubs		6.00		
26	MINIMUM CHARGE FOR ANY ONE PERMIT		50.00 ea		
27	FAILURE TO CALL FOR FINAL INSPECTION		15.00		
28	DOUBLE FEES will be charged for any work started before obtaining permit.				

Receipt #21657
TOTAL FEES 50.00

The undersigned hereby makes application for a permit for the execution of electrical installation for light, heat or power as prescribed and agrees to comply with all applicable State and Local Codes and Ordinances regulating the installation of electrical wiring and equipment in the Village of Fox Point.

MAKE CHECKS PAYABLE TO:
Treasurer, Village of Fox Point
MAIL TO: Electrical Inspector

Contractor Blaw Heating & Cooling
Address 12221 W. Fairview
City Milwaukee State WI Zip Code 53226
Supervising Electrician (Signature) [Signature] Telephone (414) 268-4040
Date

This Permit is void if work is not started within 2 months, or if started, no work is done for 2 months.

Receipt No: 1.021617

Jun 12, 2007

8401 N FOXCROFT LANE

LICENSES & PERMITS-ELECTRICAL PERMIT	50.00
24-44430 ELECTRICAL PERMIT	

Total:	50.00
--------	-------

CHECK	Chk No: 1986	50.00
Total Applied:		50.00

Change Tendered:	.00
------------------	-----

06/12/07 12:31pm

VILLAGE OF FOX POINT
7200 N. SANTA MONICA BLVD
FOX POINT, WI 53217

414-351-8900

C# 183852
S# 203257
I# 12704

#60. Receipt # 21668
VILLAGE OF FOX POINT
MILWAUKEE COUNTY, WISCONSIN

No. 6758

APPLICATION AND RECORD FOR HEATING PERMIT

TO THE BUILDING INSPECTION DEPARTMENT:

The undersigned hereby applies for a permit to install, in accordance with the information tabulated hereafter,

Winter Air Conditioner ☐ Type _____
Forced Air, Radiant, Baseboard, Etc.

Fuel: ☐ Gas ☐ Oil ☐ Coal ☐ Elect. ☐ Other _____

Desc. of Heating Plant _____

Vented to _____

Fuel Tank ☐: _____ Size _____ Location _____

Summer Air Conditioner ☒ Size (2) 2 TON Goodman A/C'S (Ton, H.P.)

Coolant R-22

Compressor Coolant: Air ☒; Water ☐;

If Water Cooled:

Source of Water _____

Discharged to _____

Location of unit on premises including distances to lot lines required for approval of exterior apparatus.

Rear of home

Incinerator ☐ Manufacturer's Name _____

Model No. _____ Capacity _____ Bushels _____

Has installation permit been issued by Milwaukee Co. Dept. of Air Pollution Control? _____

Remarks _____

The undersigned acknowledges that he is familiar with Ordinance No. 261, and all amendments thereto and that the work described herewith shall conform in all respects to said ordinances and all other ordinances of the Village of Fox Point, and laws of the State of Wisconsin. Any variations of the above may cause immediate revocation of the permit, if granted.

Owner Kathleen/Brian Hanson

Address of Work 8401 W. Fox Craft Lane

OFFICE USE ONLY

Application
Approved:

6/14/07

Installation
Approved:

9/11/07

Signed

James Blaw

Date

6/14/07

Contractor Blaw Heating/Cooling

Address 12221 W. Farview

Phone 414-288-4040

City Milwaukee State WI Zip Code 53226

Blaw

Receipt No: 1.021668

Jun 14, 2007

8401 N FOX CROFT LANE

LICENSES & PERMITS-HEATING PERMIT	60.00
24-44450 HEATING PERMIT	

Total:	60.00
--------	-------

CHECK	Chk No: 1990	60.00
Total Applied:		60.00

Change Tendered:	.00
------------------	-----

06/14/07 10:38am

VILLAGE OF FOX POINT
7200 N. SANTA MONICA BLVD
FOX POINT, WI 53217

414-351-8900

No. 95200
Plumber Self-owned
Address 8401 N. Fox Gate
Tel. No. 540-2217
Application and Record
Village of Fox Point
7200 N. Santa Monica Blvd.
Fox Point, WI 53217
351-8900

Owner Kathleen Hansen
Address 8401 N. Fox Gate
Date 8/29/01, 19 01

TO the VILLAGE OF FOX POINT, PLUMBING AND WATER INSPECTION DEPARTMENT: The undersigned hereby make application to do the work of plumbing consisting of

laying a inch laying a inch
builder sewer from Main to Lot line water service from Main to Lot line
to Building to Building
at

PERMITS USED	
Kind	No.
Sewer and Plumbing	9475
Water	
Street	
Meter	
Water Usage	

Address at which work is to be done Fox Point, Wis.

Subdivision	Lot	Block

In the performance of this work the undersigned Plumber hereby agrees to bounden by and submit to all statutes, village ordinances, and rules and regulations prescribed by the Village Board for Plumbers.

License No. Plumber

Application must be signed by licensed plumber who has current insurance certificate on file in Fox Point.

FIXTURES WITH DRAIN OR WATER CONNECTIONS			
	No.		No.
Hose Bibs		Dishwashers	
Bath Tubs		Wash Basins	
Sump Pumps		Water Closets	
Laundry Trays		Showers	
Drinking Fountains		Floor Drains	
Sinks		Food Waste Grinders	
Water Heaters		Sprinkling System	
Wash. Mach. Wastes		Urinals	
Bldets			
Catch Basins			

FEEES

Water Usage	\$
Building Sewer	
Water Service	
Building Drain	
Fixtures	
Water Meter	
Total	\$40.00
Deposit to cover street repairs	Receipt # 2334
	Permit Clerk

A inch water service pipes laid in
Curb box is located feet of feet of
inch Water Meter No. Date Installed

A inch sanitary sewer connection was made in
feet of manhole

A inch storm sewer connection was made in
feet of manhole

Building Sewer	Report	Building Drain	Report	Rough In Plumbing Inspection	Report	Final Inspection	Report

Installation Approved Application Approved, 19
As Built Water and Plumbing Inspector

REMARKS	DISCREPANCY RECORD

SEWER AND PLUMBING DEPARTMENT

Permit No. 9475 Application No. 9520 Fox Point, WI 8/29/01 20

Permission is hereby given to do the necessary plumbing work on the premises of
described as follows:

Lot Block Subdivision

Located at 8401 N. Keweenaw

The above named is permitted to employ _____

License No. _____ for the purpose of laying a _____ inch _____

Sanitary Building Sewer from Main to Curb to Lot line to Premises. Connection to be made in
_____ feet _____ of _____

Laying a _____ inch _____ Building Storm Sewer _____

Fixtures with drain or water connection:

	No.		No.		No.
Hose Bibs		Water Heaters		Water Closets	1
Bath Tubs	1	Wash Mach Waste		Showers	
Sump Pumps		Bidets		Floor Drains	
Laundry Trays		Catch Basins		Food Waste Grinders	
Drinking Fountains		Dishwashers		Sprinkling Systems	
Sinks	1	Wash Basins		Urinals	

as per application made subject to the Rules and Regulations of the Village Board and of Chapter 12 of the Fox Point Village Code.

Building Sewer \$ _____

Building Drain \$ _____

Fixtures \$ 400

Rec'd for Permit \$ _____

Receipt #

Plumbing Inspector

2334

Receipt No: 1.002334

Sep 05, 2001

8401 N FOXCROFT LANE

LICENSES & PERMITS-PLUMBING PERMIT 40.00

10-44470 PLUMBING PERMIT

Total: 40.00

CHECK Chk No: 4295 40.00

Total Applied: 40.00

Change Tendered: .00

09/05/01 10:50am

VII I AGF OF FOX POINT

VILLAGE OF FOX POINT

7200 N. SANTA MONICA BLVD.
FOX POINT 53217
414-351-8900

OFFICE USE ONLY

Permit No.	16474C
Received	1/17/02
Service	
Rough-in	
Final	

APPLICATION FOR ELECTRICAL PERMIT

Date 1-15-02
License No. # 11

PLEASE TYPE OR PRINT WITH BALL POINT PEN

Builder	Owner <u>KATHLEEN HANSEN</u>	Occupant <u>SAME</u>
Job Address <u>8401 N. Foxcraft Lane.</u>		

ESTIMATED COST OF JOB

- Buildings ☒ Residential
☐ Commercial
☐ Industrial
☐ Institutional
☐ New Construction
☐ Additional Rooms
☐ Remodeling
☐ New Occupancy

Where on Premises?

Describe BATHROOM
MEDICINE CABINET

List Name of Installing Contractor

HEATING

AIR CONDITIONING

PLUMBING

Date of Inspection

- Rough ☐ Will Call ☐
 Final ☐ Will Call ☐
 Service Approval Sent ☐

REMARKS:

C02-0644

No.	Description	Qty.	Rate of Fees	Dollars	Cents
1	Light, switch and convenience outlets	1	.35 ea		35
2	Lighting Fixtures		.30 ea		
3	Fluorescent Fixtures - per tube		.30 ea		
4	Range, Electric		4.00 ea		
5	Garbage Grinding and Disposal Unit		3.00 ea		
6	Dishwasher		4.00 ea		
7	Clothes Dryer		4.00 ea		
8	Water Heaters, Electric		4.00 ea		
9	Gas Burner, Oil Burner or Stoker		5.00 ea		
10	Refrigerating, Air Cooling or similar machine - .25 per HP		5.00 min		
11	Feeders - No. 6 A.W.G. or Larger		7.00 ea		
12	Temporary Service Permit for: How Long?		10.00 ea		
13	Services: Service Switches, ea.		5.00 ea		
	Service 1. 0 through 100 amps.		5.00 ea		
	2. 101 through 400 amps.		10.00 ea		
	3. 401 through 600 amps.		10.00 ea		
	4. 601 through 1000 amps.		15.00 ea		
	5. Thereafter, ea. additional 1000 amps.		5.00 ea		
14	Motors over 1/4 HP		.30 per HP or frac		
15	Fuel Dispensing Pumps		6.00 ea		
16	Transformers, Rectifiers and Generators		.30 per KW		
17	Space Heating Systems, per circuit		3.00 ea		
18	Power receptacles - 120 Volts or over 1. Through 30 amps		3.00 ea		
19	2. Over 30 amps		5.00 ea		
20	Wireways, busways, underfloor raceways or auxiliary gutters		.25 per ft		
21	Strip Lighting, Plug-in Strip, Trol-E Duct or similar system		.20 per ft		
22	Signs, Electric - .10 ea. socket, plus .50 ea. add'l. transformer		8.00 min		
23	Swimming Pool Wiring: A. Inground pools		40.00		
24	B. Above ground pools		25.00		
25	Spas, Hot-tubs, Hydromassage Bathtubs		6.00		
26	MINIMUM CHARGE FOR ANY ONE PERMIT		40.00 ea		
27	FAILURE TO CALL FOR FINAL INSPECTION		15.00		
28	DOUBLE FEES will be charged for any work started before obtaining permit.				

Receipt # 3247
 TOTAL FEES 40 00

The undersigned hereby makes application for a permit for the execution of electrical installation for light, heat or power as prescribed and agrees to comply with all applicable State and Local Codes and Ordinances regulating the installation of electrical wiring and equipment in the Village of Fox Point.

MAKE CHECKS PAYABLE TO:
 Treasurer, Village of Fox Point
 MAIL TO: Electrical Inspector

Contractor <u>ROMAN Electric Co</u>	Supervising Electrician (Signature) <u>Roman P. Roman</u>	Date <u>1-16-02</u>
Address <u>640 S 70TH ST.</u>	Telephone <u>414-771-5400</u>	
City <u>MILWAUKEE</u>	State <u>WI</u>	Zip Code <u>53214</u>

This Permit is void if work is not started within 2 months, or if started, no work is done for 2 months.

Receipt No: 1.003247

Jan 18, 2002

8401 N FOXCROFT LANE

LICENSES & PERMITS-ELECTRICAL PERMIT	40.00
10-44430 ELECTRICAL PERMIT	

Total:	<u>40.00</u>
--------	--------------

CHECK	Chk No: 002715	40.00
Total Applied:		<u>40.00</u>

Change Tendered:	<u>.00</u>
------------------	------------

01/17/02 01:42pm

VILLAGE OF FOX POINT
7200 N. SANTA MONICA BLVD
FOX POINT, WI 53217

414-351-8900

VILLAGE OF FOX POINT

MILWAUKEE COUNTY, WISCONSIN

No. 11397

APPLICATION FOR BUILDING PERMIT

TO THE BUILDING INSPECTION DEPARTMENT:

The undersigned hereby applies for a permit to build, in accordance with the information tabulated hereafter,

XType of Structure Residence
Residence, Garage, Store, Office, School, Fence, Shed, Sign, Swimming Pool, Etc.

XAddress 8401 N. Fox Creek

Lot _____ Block _____

Subdivision _____

District _____

Does contemplated structure violate the Village zoning ordinance? _____

Height of Structure _____ (stories or feet)

Width (parallel to highway) _____ (feet) Depth (perpendicular to highway) _____ (feet)

Distance: Street Line to Front Line of Structure _____ (feet)

Distance: Side Lot Line to Structure _____

Type of Construction: _____ Exterior finish _____
Frame, Brick-tile, Etc. Stucco, Siding, Brick Veneer, Etc.

Height of front yard above street grade _____

Number of rooms _____ Baths _____

Garage _____

XEstimated cost Building _____

Structure \$2,000

Is there a private garage? _____

Does the contemplated garage violate the Village zoning ordinance? _____

Size _____ Number of stalls _____

Where situated _____

General construction _____
Frame — Brick — Stucco — Etc.

Have plans been submitted to the Wisconsin Department of Industry, Labor and Human Relations for examination and approval? _____

Have plans been approved as being in compliance with all applicable sections of the Wisconsin Administrative code? _____

Herewith are filed the following duplicate plans _____ in number, which I certify I will conform to in the work hereby applied for.

XRemarks: Remove & replace drywall, flooring, w/b toilet, sink, faucets

Herewith are filed the specifications that describe the work in question and as shown on plans above submitted.

In making the application the undersigned agrees to obey the Fox Point Building and Zoning Codes pertaining to the erection of all structures and also agrees to obey all other ordinances of the Village of Fox Point.

The undersigned, owner or being duly authorized so to do, hereby gives express authorization to the Village of Fox Point, its officers, agents and employees, to enter upon the premises herein described and fill up any excavation, or tear down, remove or enclose the unfinished structure for which a permit is herein requested in the event of cessation of the building, whenever the Building Inspector shall determine that such premises in the unfinished condition of the structure are dangerous to members of the public, including children, even though trespassers. The undersigned further hereby waives all statutory notices and consents to the determination by the Village Board and the levy and placing upon the tax roll of a special assessment in the amount of the cost to the Village, including customary Village overhead charges incurred in filling up any such excavation or tearing down, removing or enclosing any such unfinished structure.

We hereby agree to provide a house number plate or sign readily observable from the public highway which will be installed not less than 15 days after the structure is occupied.

X Owner of Structure Kathleen Hansen Arch. or Contr. _____

Address 8401 N. Fox Creek Ln Address _____

City _____ State _____ Zip _____

Phone 540-2217 Phone _____

Size of Structure _____ (sq. ft.) Permit Fee \$40.00 Rec# 2218 herewith tendered

Date Submitted 8/21/08 State ID# _____ Exp. Date _____

Date Approved _____ X Signed Kathleen Hansen

Date of Permit _____ Architect, Owner, Builder

VILLAGE OF FOX POINT

7200 N. SANTA MONICA BLVD.
FOX POINT 53217
414-351-8900

OFFICE USE ONLY

Permit No. 15377
Received 3/24/99
Service _____
Rough-in _____
Final _____

APPLICATION FOR ELECTRICAL PERMIT

Date 3/1/99

PLEASE TYPE OR PRINT WITH BALL POINT PEN

License No. _____

Builder AIR COMFORT SYSTEMS Owner KATHLEEN HANSEN Occupant KATHLEEN HANSEN
Job Address 8401 N FOXCROFT LANE, FOX POINT

ESTIMATED COST OF JOB

- Buildings ☒ Residential
☐ Commercial
☐ Industrial
☐ Institutional
☐ New Construction
☐ Additional Rooms
☒ Remodeling
☐ New Occupancy

Where on Premises?

Describe Furnace Replacements

List Name of Installing Contractor

HEATING AIR COMFORT SYSTEMS
AIR CONDITIONING _____
PLUMBING _____

Date of Inspection

- Rough _____ Will Call ☐
Final _____ Will Call ☒
Service Approval Sent _____ ☐

REMARKS:

No.	Description	Qty.	Rate of Fees	Dollars	Cents
1	Light, switch and convenience outlets		.35 ea		
2	Lighting Fixtures		.30 ea		
3	Fluorescent Fixtures - per tube		.30 ea		
4	Range, Electric		4.00 ea		
5	Garbage Grinding and Disposal Unit		3.00 ea		
6	Dishwasher		4.00 ea		
7	Clothes Dryer		4.00 ea		
8	Water Heaters, Electric		4.00 ea		
9	Gas Burner, Oil Burner or Stoker	1	5.00 ea	5	
10	Refrigerating, Air Cooling or similar machine - .25 per HP		5.00 min		
11	Feeders - No. 6 A.W.G. or Larger		7.00 ea		
12	Temporary Service Permit for: How Long?		10.00 ea		
13	Services: Service Switches, ea.		5.00 ea		
	Service 1. 0 through 100 amps.		5.00 ea		
	2. 101 through 400 amps.		10.00 ea		
	3. 401 through 600 amps.		10.00 ea		
	4. 601 through 1000 amps.		15.00 ea		
	5. Thereafter, ea. additional 1000 amps.		5.00 ea		
14	Motors over 1/4 HP		.30 per HP or frac		
15	Fuel Dispensing Pumps		6.00 ea		
16	Transformers, Rectifiers and Generators		.30 per KW		
17	Space Heating Systems, per circuit		3.00 ea		
18	Power receptacles - 120 Volts or over 1. Through 30 amps		3.00 ea		
19	2. Over 30 amps		5.00 ea		
20	Wireways, busways, underfloor raceways or auxillary gutters		.25 per ft		
21	Strip Lighting, Plug-in Strip, Trol-E Duct or similar system		.20 per ft		
22	Signs, Electric - .10 ea. socket, plus .50 ea. add'l. transformer		8.00 min		
23	Swimming Pool Wiring: A. Inground pools		40.00		
24	B. Above ground pools		25.00		
25	Spas, Hot-tubs, Hydromassage Bathtubs		6.00		
26	MINIMUM CHARGE FOR ANY ONE PERMIT		40.00 ea		
27	FAILURE TO CALL FOR FINAL INSPECTION		15.00		
28	DOUBLE FEES will be charged for any work started before obtaining permit.				

Receipt # 25440
TOTAL FEES 80.00

The undersigned hereby makes application for a permit for the execution of electrical installation for light, heat or power as prescribed and agrees to comply with all applicable State and Local Codes and Ordinances regulating the installation of electrical wiring and equipment in the Village of Fox Point.

MAKE CHECKS PAYABLE TO:
Treasurer, Village of Fox Point
MAIL TO: Electrical Inspector

Contractor AIR COMFORT SYSTEMS Supervising Electrician (Signature) [Signature] Date 3/3/99 3/3
Address 635 S. 20TH ST. Telephone 7784180
City MILWAUKEE State WI Zip Code 53214

This Permit is void if work is not started within 2 months, or if started, no work is done for 2 months.

VILLAGE OF FOX POINT

Receipt #: 25440

March 23 1999

Received of : AIR COMFORT SYSTEMS, INC.

Amount

Eighty and 00/100----- \$*****80.00

CATEGORY NUMBER

ACCOUNT NUMBER

AMOUNT

120

R1044430

40.00

CHECK:

80.00

120

R1044450

40.00

7200 N SANTA MONICA BLVD, CLERK-TREASURER

Have a Nice Day
and thank you very much

OFFICIAL RECEIPT WHEN VALIDATED IN THIS BOX

MDP 03/23/1999 4:14 PM *****80.00

VILLAGE OF FOX POINT

Receipt #: 25439

March 23 1999

Received of : AIR COMFORT SYSTEMS, INC.

Amount

Eighty and 00/100----- \$*****80.00

CATEGORY NUMBER

ACCOUNT NUMBER

AMOUNT

120

R1044430

40.00

CHECK:

80.00

120

R1044450

40.00

7200 N SANTA MONICA BLVD, CLERK-TREASURER

Have a Nice Day
and thank you very much

OFFICIAL RECEIPT WHEN VALIDATED IN THIS BOX
MDP 03/23/1999 4:13 PM *****80.00

#80.00 - Receipts # 25439 + 25440

VILLAGE OF FOX POINT
MILWAUKEE COUNTY, WISCONSIN

No. 5499C

APPLICATION AND RECORD FOR HEATING PERMIT

TO THE BUILDING INSPECTION DEPARTMENT:

The undersigned hereby applies for a permit to install, in accordance with the information tabulated hereafter,

Winter Air Conditioner ☒ Type FORCED AIR
Forced Air, Radiant, Baseboard, Etc.

Fuel: ☒ Gas ☐ Oil ☐ Coal ☐ Elect. ☐ Other

Desc. of Heating Plant Lennox G26Q380

Vented to DIRECT VENT

Fuel Tank ☐: N/A Size Location

Summer Air Conditioner ☐ Size (Ton, H.P.)

Coolant

Compressor Coolant: Air ☐; Water ☐;

If Water Cooled: Source of Water BB 40

Discharged to

Location of unit on premises including distances to lot lines required for approval of exterior apparatus.

Incinerator ☐ Manufacturer's Name

Model No. Capacity Bushels

Has installation permit been issued by Milwaukee Co. Dept. of Air Pollution Control?

Remarks

The undersigned acknowledges that he is familiar with Ordinance No. 261, and all amendments thereto and that the work described herewith shall conform in all respects to said ordinances and all other ordinances of the Village of Fox Point, and laws of the State of Wisconsin. Any variations of the above may cause immediate revocation of the permit, if granted.

Owner KATHLEEN HANSEN

Address of Work 8401 N. FOXCROFT LANE

OFFICE USE ONLY	
Application Approved: <u>3/23/99</u>	Installation Approved: <u>7/23/99</u>

[Signature] Signed
3/3/99 Date

Contractor AIR COMFORT SYSTEMS

Address 635 S. 70TH ST., MILWAUKEE, WI 53214 Phone 7784180

City MILWAUKEE State WI Zip Code 53214

VILLAGE OF FOX POINT

Receipt #: 25439

March 23 1999

Received of : AIR COMFORT SYSTEMS, INC.

Amount

Eighty and 00/100----- \$*****80.00

CATEGORY NUMBER

ACCOUNT NUMBER

AMOUNT

120

R1044430

40.00

CHECK:

80.00

120

R1044450

40.00

7200 N SANTA MONICA BLVD, CLERK-TREASURER

Have a Nice Day
and thank you very much

OFFICIAL RECEIPT WHEN VALIDATED IN THIS BOX
MDP 03/23/1999 4:13 PM *****80.00

VILLAGE OF FOX POINT

Receipt #: 25440

March 23 1999

Received of : AIR COMFORT SYSTEMS, INC.

Amount

Eighty and 00/100----- \$*****80.00

CATEGORY NUMBER

ACCOUNT NUMBER

AMOUNT

120

R1044430

40.00

CHECK:

80.00

120

R1044450

40.00

7200 N SANTA MONICA BLVD, CLERK-TREASURER

Have a Nice Day
and thank you very much

OFFICIAL RECEIPT WHEN VALIDATED IN THIS BOX
MDP 03/23/1999 4:14 PM *****80.00

INSPECTION DEPARTMENT
VILLAGE OF FOX POINT
7200 N. SANTA MONICA BOULEVARD
FOX POINT, WI 53217
NONCOMPLIANCE NOTICE


March 4, 1999

Issued to: Bruce Myslis

Address: 9106 N. Port Washington Road, Milwaukee, WI 53217

An inspection of the premises located at 8401 N. Fox Croft Lane discloses non-compliance with Codes or Ordinances of the Village of Fox Point as hereinafter listed:

1. Please obtain the required heating and electrical permits for the installation of the new furnace.



Scott Miller
Building Inspector
Village of Fox Point

INSPECTION DEPARTMENT
VILLAGE OF FOX POINT
7200 N. SANTA MONICA BOULEVARD
FOX POINT, WISCONSIN 53217

CERTIFICATE OF COMPLIANCE


March 17, 1999

NO. 4336

Issued to: Bruce Myslis

Address: 9106 N. Port Washington Road, Bayside WI 53217

This Certificate of Compliance permits a change in the occupancy of the premises located at 8401 N. Fox Croft Lane, Fox Point, Wisconsin, any time within one year from the date hereof, and indicates that so far as can reasonably be determined by a visual inspection of the premises and a review of the Village records, the premises meet the requirements of Section 30P.62 of the Fox Point Building Code. This certificate is issued for the benefit of the Village of Fox Point in the enforcement of Section 30P.62 of the Fox Point Building Code. Neither the Village of Fox Point nor the Building Inspector assumes any liability in or as a result of the inspection or issuance of the Certificate of Compliance and by the issuance of this Certificate of Compliance does not guarantee or warrant as to the condition of the premises inspected.



Scott Miller
Building Inspector
Village of Fox Point

VILLAGE OF FOX POINT

7200 N. SANTA MONICA BLVD.
FOX POINT 53217
414-351-8900

OFFICE USE ONLY

Permit No.	14572C
Received	2/24/97
Service	
Rough-in	
Final	

APPLICATION FOR ELECTRICAL PERMIT

PLEASE TYPE OR PRINT WITH BALL POINT PEN

Date 2-24-97
License No. 114

Builder <u>N/A</u>	Owner <u>Bruce Myslis</u>	Occupant <u>VACANT</u>
Job Address <u>8401 N FOX CROFT LAINE</u>		

ESTIMATED COST OF JOB

- Buildings ☐ Residential
☐ Commercial
☐ Industrial
☐ Institutional
☐ New Construction
☐ Additional Rooms
☐ Remodeling
☐ New Occupancy

Where on Premises?

Describe 2-17-97

CODE COMPLIANCE
LETTER - SCOTT MILLER

List Name of Installing Contractor

HEATING _____

AIR CONDITIONING _____

PLUMBING _____

Date of Inspection

- Rough _____ Will Call ☐
Final _____ Will Call ☐
Service Approval Sent _____ ☐

REMARKS:

No.	Description	Qty.	Rate of Fees	Dollars	Cents
1	Light, switch and convenience outlets		.35 ea		
2	Lighting Fixtures		.30 ea		
3	Fluorescent Fixtures - per tube		.30 ea		
4	Range, Electric		4.00 ea		
5	Garbage Grinding and Disposal Unit		3.00 ea		
6	Dishwasher		4.00 ea		
7	Clothes Dryer		4.00 ea		
8	Water Heaters, Electric		4.00 ea		
9	Gas Burner, Oil Burner or Stoker		5.00 ea		
10	Refrigerating, Air Cooling or similar machine - .25 per HP		5.00 min		
11	Feeders - No. 6 A.W.G. or Larger		7.00 ea		
12	Temporary Service Permit for: How Long?		10.00 ea		
13	Services: Service Switches, ea.		5.00 ea		
	Service 1. 0 through 100 amps.		5.00 ea		
	2. 101 through 400 amps.		10.00 ea		
	3. 401 through 600 amps.		10.00 ea		
	4. 601 through 1000 amps.		15.00 ea		
	5. Thereafter, ea. additional 1000 amps.		5.00 ea		
14	Motors over 1/4 HP		.30 per HP or frac		
15	Fuel Dispensing Pumps		6.00 ea		
16	Transformers, Rectifiers and Generators		.30 per KW		
17	Space Heating Systems, per circuit		3.00 ea		
18	Power receptacles - 120 Volts or over 1. Through 30 amps		3.00 ea		
19	2. Over 30 amps		5.00 ea		
20	Wireways, busways, underfloor raceways or auxillary gutters		.25 per ft		
21	Strip Lighting, Plug-in Strip, Trol-E Duct or similar system		.20 per ft		
22	Signs, Electric - .10 ea. socket, plus .50 ea. add'l. transformer		8.00 min		
23	Swimming Pool Wiring: A. Inground pools		40.00		
24	B. Above ground pools		25.00		
25	Spas, Hot-tubs, Hydromassage Bathtubs		6.00		
26	MINIMUM CHARGE FOR ANY ONE PERMIT		40.00 ea	40	00
27	FAILURE TO CALL FOR FINAL INSPECTION		15.00		
28	DOUBLE FEES will be charged for any work started before obtaining permit.				

Receipt #10526
TOTAL FEES 40 00

The undersigned hereby makes application for a permit for the execution of electrical installation for light, heat or power as prescribed and agrees to comply with all applicable State and Local Codes and Ordinances regulating the installation of electrical wiring and equipment in the Village of Fox Point.

LAKE SIDE ELECTRIC SVC

Contractor Box 226

Address

City BELGIUM

State WI

Zip Code 53004

Telephone

414-285-3400

Supervising Electrician (Signature)

MAKE CHECKS PAYABLE TO:
Treasurer, Village of Fox Point
MAIL TO: Electrical Inspector

Date 2-24-97

This Permit is void if work is not started within 2 months, or if started, no work is done for 2 months.

VILLAGE OF FOX POINT

Receipt #: 10526

February 24 1997

Received of : LAKESIDE ELECTRIC

Amount

Forty and 00/100----- \$*****40.00

CATEGORY NUMBER

ACCOUNT NUMBER

AMOUNT

120

R1044430

40.00

CHECK:

40.00

VILLAGE OF FOX POINT

Have a Nice Day
and thank you very much

OFFICIAL RECEIPT WHEN VALIDATED IN THIS BOX

MDP 02/24/1997 12:00 PM *****40.00


INSPECTION DEPARTMENT
VILLAGE OF FOX POINT
7200 N. SANTA MONICA BOULEVARD
FOX POINT, WI 53217
NONCOMPLIANCE NOTICE
February 17, 1997

Issued to: Bruce Myslis/Mitchell Savings Bank

Address: 9106 N. Port Washington Road, Milwaukee, WI 53217

An inspection of the premises located at 8401 N. Fox Croft Lane discloses noncompliance with Codes or Ordinances of the Village of Fox Point as hereinafter listed:

- removed, sump pump being removed.*
1. All basement fluorescent light fixtures must be installed in accordance with code.
 2. Smoke detectors are required for each floor level including the basement.
 3. Provide backflow protection for all exterior hose bibs and laundry tub faucets.
 4. The armored cable installed in the basement below the floor joist must comply with code.
 5. The basement recreation room outlet must be properly grounded.
 6. The dining room electrical outlet must be securely attached to the north exterior wall.
 7. Properly repair the hole in the garage firewall.
 8. All downspouts must expire at least 3'00" from the dwelling.
 9. The sump pump must discharge at least 3'00" from the dwelling.
 10. Repair/replace damaged downspout attached to the south east corner of the dwelling.



Scott Miller
Building Inspector
Village of Fox Point

INSPECTION DEPARTMENT
VILLAGE OF FOX POINT
7200 N. SANTA MONICA BOULEVARD
FOX POINT, WISCONSIN 53217

CERTIFICATE OF COMPLIANCE


February 27, 1997

NO. 4018

Issued to: Mitchell Savings Bank/Ruuce Myslis

Address: 9106 N. Port Washington Road, Milwaukee, WI 53217

This Certificate of Compliance permits a change in the occupancy of the premises located at 8401 N. Fox Croft Lane., Fox Point, Wisconsin, any time within one year from the date hereof, and indicates that so far as can reasonably be determined by a visual inspection of the premises and a review of the Village records, the premises meet the requirements of Section 30P.62 of the Fox Point Building Code. This certificate is issued for the benefit of the Village of Fox Point in the enforcement of Section 30P.62 of the Fox Point Building Code. Neither the Village of Fox Point nor the Building Inspector assumes any liability in or as a result of the inspection or issuance of the Certificate of Compliance and by the issuance of this Certificate of Compliance does not guarantee or warrant as to the condition of the premises inspected.



Scott Miller
Building Inspector
Village of Fox Point

INSPECTION DEPARTMENT
VILLAGE OF FOX POINT
7200 N. SANTA MONICA BOULEVARD
FOX POINT, WISCONSIN 53217

NONCOMPLIANCE NOTICE

August 13, 1993
Date


Issued to: Thomas and Veronica Van Dalen

Address: 8401 N. Foxcroft Lane

An inspection of the premises located at 8401 N. Foxcroft Lane
discloses noncompliance with Codes or Ordinances of the Village of Fox Point as
hereinafter listed:

1. Seal all gas leaks.
2. Service drop shall be raised to a height of not less than 12'0"
from grade.

The premises at the above address shall be brought in compliance before there
is a change in occupancy. Please notify this office when corrections have been
made and a reinspection of the premises for compliance is desired.


Building Inspector - Village of Fox Point

INSPECTION DEPARTMENT
VILLAGE OF FOX POINT
7200 N. SANTA MONICA BOULEVARD
FOX POINT, WISCONSIN 53217

CERTIFICATE OF COMPLIANCE

No. 3396 Date August 23, 1993

Issued to Thomas and Veronica Van Dalen

Address 8401 N. Foxcroft Lane

This Certificate of Compliance permits a change in the occupancy of the premises located at 8401 N. Foxcroft Lane in Fox Point, Wisconsin, any time within one year from the date hereof, and indicates that so far as can reasonably be determined by a visual inspection of the premises and a review of the Village records, the premises meet the requirements of Section 30P.62 of the Fox Point Building Code. This certificate is issued for the benefit of the Village of Fox Point in the enforcement of Section 30P.62 of the Fox Point Building Code. Neither the Village of Fox Point nor the Building Inspector assumes any liability in or as a result of the inspection or issuance of this Certificate of Compliance and by the issuance of this Certificate of Compliance does not guarantee or warrant as to the condition of the premises inspected.



Building Inspector
Village of Fox Point

VILLAGE OF FOX POINT

7200 N. SANTA MONICA BLVD.
FOX POINT 53217
414-351-8900

OFFICE USE ONLY

Permit No.	12374 <i>OC</i>
Received	5-2-91
Service	5-15-91
Rough-in	
Final	

APPLICATION FOR ELECTRICAL PERMIT

PLEASE TYPE OR PRINT WITH BALL POINT PEN

Date 5/1/91
License No. 76

Builder CIRCLE ELECTRIC CO. INC.	Owner TOM VAN DALEN	Occupant SAME
Job Address 8401 N. FOX CROFT		

ESTIMATED COST OF JOB **\$ 700**

Buildings ☒ Residential

- ☐ Commercial
☐ Industrial
☐ Institutional
☐ New Construction
☐ Additional Rooms
☐ Remodeling
☐ New Occupancy

Where on Premises? **OUTSIDE/BASEMENT**

Describe **CHANGE SERVICE
TO 200AMP & CONNECT
1- A/C CENTRAL AIR UNIT**

List Name of Installing Contractor

HEATING

AIR CONDITIONING

PLUMBING

Date of Inspection

Rough ☒ Will Call ☒
Final ☒ Will Call ☒
Service Approval Sent ☐

REMARKS:

**CEI Job
G-778**

No.	Description	Qty.	Rate of Fees	Dollars	Cents
1	Light, switch and convenience outlets		.35 ea		
2	Lighting Fixtures		.30 ea		
3	Fluorescent Fixtures - per tube		.30 ea		
4	Range, Electric		4.00 ea		
5	Garbage Grinding and Disposal Unit		3.00 ea		
6	Dishwasher		4.00 ea		
7	Clothes Dryer		4.00 ea		
8	Water Heaters, Electric		4.00 ea		
9	Gas Burner, Oil Burner or Stoker		5.00 ea		
10	Refrigerating, Air Cooling or similar machine - .25 per HP	1	5.00 min	5	00
11	Feeders - No. 6 A.W.G. or Larger		7.00 ea		
12	Temporary Service Permit for: How Long?		10.00 ea		
13	Services: Service Switches, ea.		5.00 ea		
	Service 1. 0 through 100 amps.		5.00 ea		
	2. 101 through 400 amps.	1	10.00 ea	10	00
	3. 401 through 600 amps.		10.00 ea		
	4. 601 through 1000 amps.		15.00 ea		
	5. Thereafter, ea. additional 1000 amps.		5.00 ea		
14	Motors over 1/4 HP		.30 per HP or trac		
15	Fuel Dispensing Pumps		6.00 ea		
16	Transformers, Rectifiers and Generators		.30 per KW		
17	Space Heating Systems, per circuit		3.00 ea		
18	Power receptacles - 120 Volts or over 1. Through 30 amps		3.00 ea		
19	2. Over 30 amps		5.00 ea		
20	Wireways, busways, underfloor raceways or auxiliary gutters		.25 per ft		
21	Strip Lighting, Plug-in Strip, Trol-E Duct or similar system		.20 per ft		
22	Signs, Electric - .10 ea. socket, plus .50 ea. add'l. transformer		8.00 min		
23	Swimming Pool Wiring: A. Inground pools		40.00		
24	B. Above ground pools		25.00		
25	Spas, Hot-tubs, Hydromassage Bathtubs		6.00		
26	MINIMUM CHARGE FOR ANY ONE PERMIT		20.00 ea		
27	FAILURE TO CALL FOR FINAL INSPECTION		15.00		
28	DOUBLE FEES will be charged for any work started before obtaining permit.				

TOTAL FEES **20 00**

The undersigned hereby makes application for a permit for the execution of electrical installation for light, heat or power as prescribed and agrees to comply with all applicable State and Local Codes and Ordinances regulating the installation of electrical wiring and equipment in the Village of Fox Point.

MAKE CHECKS PAYABLE TO:
Treasurer, Village of Fox Point
MAIL TO: Electrical Inspector

Contractor CIRCLE ELECTRIC CO INC.	Supervising Electrician (Signature) <i>[Signature]</i>	Date 5/1/91
Address 1060 N. 115TH STREET	Telephone 414-453-1060	
City MILWAUKEE	State WI.	Zip Code 53226

This Permit is void if work is not started within 2 months, or if started, no work is done for 2 months.

Wisconsin Electric Power Company
OUTLET LOCATION LETTER

☐ REVISION
☐ DUPLICATE

To: Circle Electric Date Prepared 4 -
In regard to your inquiry of 4/10/91 for (Overhead) (Underground) service to the (industrial)
(commercial) (residential) (farm) premise of Tom Van Dusen
located at 8401 N Foxcroft Ln
in the C/T/V of Fox Point we require service termination as follows:

☐ New ☐ Temporary ☒ Rewired ☐ Additional
Single Phase 200 amperes, 120/240 _____ volts, termination located _____

Same Location
☒ at 15 foot minimum above (ground) (final grade)
☒ per Electric Service and Metering Manual Sheets 0-20, 0-21
☐ Meter Location (out) (in) side at: _____

Service (drop) (lateral) size 40 AL length 100 FT tension 555 LBS

Maximum Single-phase Available Short Circuit Current at the service termination.

☒ 10,000 amperes ☐ 22,000 amperes _____ amperes

☐ New ☐ Temporary ☐ Rewired ☐ Additional ☐ Power
(Single) (Three) Phase _____ amperes (240) (120/208) (480) _____ volts, termination located _____

☐ at _____ foot minimum above (ground) (final grade).
☐ per Electric Service and Metering Manual Sheets _____
☐ Meter Location (out) (in) side at: _____

Service (drop) (lateral) size _____ length _____ tension _____

Maximum (Single) (Three) phase Available Short Circuit Current at the service termination.

☐ 22,000 amperes ☐ 25,000 amperes _____ amperes

☐ Installation of WE facilities involves (additional) charges. Billing must be satisfied prior to construction.

☐ The above information is valid for _____.

☐ The above information is contingent upon right-of-way.

☒ The above information is contingent upon new attachment height of 15 FT

☐ You are advised NOT to proceed with completion of wiring until notified the contingencies noted above have been removed.

☐ On _____ you were advised not to proceed with the completion of the wiring. All the contingencies have been removed and you may proceed.

☒ You may proceed with the completion of wiring.

☐ The location of service drops supports for buildings covered with aluminum, stucco, asbestos, or other similar siding material shall be marked. Mounting bolts were provided by the Company and shall be installed by the owner, or by his contractor for him, on brick and stone buildings.

Refer Inquiries to Don Kadeka

NOTICE TO CUSTOMER/ELECTRICIAN

Prepared by Catunet District

Phone 354-8100

Information provided in this letter does not supersede the National, State or Local Electrical Codes. The final responsibility for compliance with the various electrical codes lies with the customer and/or the customer's electrician.

Clerk: Send this form to _____

G-778

Inspector of Buildings Department

Certificate of Electrical Inspection

To Wis. Elec. Power Co.: Relative to

Premises 8401 N Fox Croft Fox Point

Owner TOM VAN DALOW

This is to Certify, that electrical work done under Permit No. 17374 issued by this

DEPARTMENT to Circle Electric is in conformity with the provisions of the Electrical Code of the Village of Fox Point, Milwaukee County, Wisconsin.

INSTALL:

☐ Service to Temporary Pole ☐ Temporary Service and Meter to Building ☒ Permanent Service to Building ☐ Hot Water Heater Service and Meter ☐ Other

Remarks:

Dated 5-15-91, 19

[Signature]
Electrical Inspector, Village of Fox Point.

APPLICATION FOR INSPECTION AND ISSUANCE OF CERTIFICATE OF COMPLIANCE

Signature Scott M. ...

INSPECTION DEPARTMENT
VILLAGE OF FOX POINT
7200 N. SANTA MONICA BOULEVARD
FOX POINT, WISCONSIN 53217

NONCOMPLIANCE NOTICE

May 4, 1990

Date


Issued to: Suzanne Fleming

Address: 8401 N. Fox Croft Lane

An inspection of the premises located at 8401 N. Fox Croft Lane discloses noncompliance with Codes or Ordinances of the Village of Fox Point as hereinafter listed:

- ~~1.~~ Remove non-metallic cable in basement as per code.
- ~~2.~~ Provide backflow protection where required by code.
- ~~3.~~ Rewire basement shop receptacle and upstairs bathroom receptacle to comply with code.
- ~~4.~~ Remove temporary basement lites.
- ~~5.~~ A code complying receptacle is required for the garage door opener.
- ~~6.~~ The maximum uniform rise for a step is 8". The rear steps are excessive and shall be brought into compliance with code.
- ~~7.~~ Rain gutters shall be installed to comply with Fox Point Code.
- ~~8.~~ Code complying ~~receptacles~~ ^{Smoke Detectors} are required for each floor level including the basement.

The premises at the above address shall be brought in compliance before there is a change in occupancy. Please notify this office when corrections have been made and a reinspection of the premises for compliance is desired.



Building Inspector - Village of Fox Point

INSPECTION DEPARTMENT
VILLAGE OF FOX POINT
7200 N. SANTA MONICA BOULEVARD
FOX POINT, WISCONSIN 53217

CERTIFICATE OF COMPLIANCE

No. 2803 Date June 1, 1990
Issued to Suzanne R. Fleming
Address 8401 N. Fox Croft Lane

This Certificate of Compliance permits a change in the occupancy of the premises located at 8401 N. Fox Croft Lane in Fox Point, Wisconsin, any time within one year from the date hereof, and indicates that so far as can reasonably be determined by a visual inspection of the premises and a review of the Village records, the premises meet the requirements of Section 30P.62 of the Fox Point Building Code. This certificate is issued for the benefit of the Village of Fox Point in the enforcement of Section 30P.62 of the Fox Point Building Code. Neither the Village of Fox Point nor the Building Inspector assumes any liability in or as a result of the inspection or issuance of this Certificate of Compliance and by the issuance of this Certificate of Compliance does not guarantee or warrant as to the condition of the premises inspected.



Building Inspector
Village of Fox Point

APPLICATION FOR HEATING PERMIT

TO THE BUILDING INSPECTION DEPARTMENT:

The undersigned hereby applies for a permit to install, in accordance with the information tabulated hereafter,

Winter Air Conditioner ☐

Fuel: ☒ Gas ☐ Oil ☐ Coal ☐ : Other _____

Type: Forced air
Forced Air, Radiant, Baseboard, Etc.

? Desc. of Heating Plant 1-170-105-and 1-170-080 Mueller Furnaces

? Vented to Chimney

Fuel Tank ☐ : _____
Size _____ Location _____

Summer Air Conditioner ☐

Size _____ (Ton, H.P.)

Coolant _____

Compressor Coolant: Air ☐ ; Water ☐ ;

If Water Cooled:

Source of Water _____

Discharged to _____

Remarks 2 gas furnaces
ISN'T THERE TWO FURNACES GOING IN THIS
JOB ? — IF THERE IS, THE FEE IS \$10.00
ALSO FILL OUT APPLICATION COMPLETELY.

The undersigned acknowledges that he is familiar with Ordinance No. 261, and all amendments thereto and that the work described herewith shall conform in all respects to said ordinances and all other ordinances of the Village of Fox Point, and laws of the State of Wisconsin. Any variations of the above may cause immediate revocation of the permit, if granted.

Owner Don Lowers

Address of Work 8401 - N. 704 Craft

? Part of Lot 5 and vacated portion of west Dean Rd. In Foxcroft Highland Sub.
Lot _____ Block _____ Subdivision _____

Contractor Fred A Bouchert 11tg

Address 5005 N 23 St. Milwaukee, Wis Phone 462-5927

Approved:

1-30-69

Fred A Bouchert
Signed

? 1/20/69
Date

APPLICATION FOR HEATING PERMIT

TO THE BUILDING INSPECTION DEPARTMENT:

The undersigned hereby applies for a permit to install, in accordance with the information tabulated hereafter,

Winter Air Conditioner ☐ Type _____
Forced Air, Radiant, Baseboard, Etc.

Fuel: ☒ Gas ☐ Oil ☐ Coal ☐ Elect. ☐ Other _____

Desc. of Heating Plant Whirlpool NB Ju 100 AF

Vented to Chimney

Fuel Tank ☐: _____
Size _____ Location _____

Summer Air Conditioner ☐ Size Whirlpool NCAEAB4 (Ton, H.P.) 2 Ton

Coolant R 22

Compressor Coolant: Air ☒; Water ☐;

If Water Cooled:

Source of Water _____

Discharged to _____

Location of unit on premises including distances to lot lines required for approval of exterior apparatus.

Incinerator ☐ Manufacturer's Name _____

Model No. _____ Capacity _____ Bushels

Has installation permit been issued by Milwaukee Co. Dept. of Air Pollution Control? _____

Remarks _____

The undersigned acknowledges that he is familiar with Ordinance No. 261, and all amendments thereto and that the work described herewith shall conform in all respects to said ordinances and all other ordinances of the Village of Fox Point, and laws of the State of Wisconsin. Any variations of the above may cause immediate revocation of the permit, if granted.

Owner SUZ FLEMING

Address of Work 8401 N. FOXCROFT LA FOXPOINT

Lot _____ Block _____ Subdivision _____

Contractor PETRI'S HEATING & COOLING

Address 4872 S. PACKARD Phone 321-7110

CODAHY WIS 53110

Approved: _____

Rec. # 15651
15.00


P. D. Quance Petri
Signed

6-25-86

6/25/86

Date

← N



INSPECTION DEPARTMENT
7200 N. SANTA MONICA BLVD.
FOX POINT, WI 53217

(414) 351-8900

APPLICATION FOR INSPECTION AND
ISSUANCE OF CERTIFICATE OF COMPLIANCE

Date 3-2-99
Building Address 8401 N Fox Cleft Ln
Owner of Building Bruce Myslis
Owner's Address if different than above 9106 N Port
Washington Rd - Milwaukee WI
53217
Building Owner's Telephone (414) 305-3057
Proposed Occupant's Name (if known) Brian Hansen
Proposed Occupant's Address _____
Proposed Occupant's Telephone ()

If a certificate of compliance will not be issued unless repairs or alterations are performed, they will be made by:

Owner ☒ Proposed Occupant _____ Other _____

B. Myslis 9106 N Port Wash. Rd Milwaukee WI
Applicant's Signature Applicant's Address
53217

NOTE: A copy of a Certificate of Compliance or Notice of Noncompliance will be given to all persons named above.

For Office Use Only:

No. 4372 Date Received 3/2/99
Amount \$100.00 Receipt 25134
Inspection made 3/4/99
Signature [Signature]

*Exemption
K. Brown
500 W. Brady St.
A 302*

Chambers

10

2

INSPECTION DEPARTMENT
7200 N. SANTA MONICA BLVD.
FOX POINT, WI 53217

(414) 351-8900

APPLICATION FOR INSPECTION AND
ISSUANCE OF CERTIFICATE OF COMPLIANCE

Date 2-11-97

Building Address 8401 N Fox Croft Ln.

Owner of Building Mitchell Savings Bank

Owner's Address if different than above _____

9106 N Port Washington Rd. Milwaukee, WI 53217

Building Owner's Telephone () _____

Proposed Occupant's Name (if known) Bruce Myslis

Proposed Occupant's Address 9106 N Port Washington Rd Milwaukee 53217

Proposed Occupant's Telephone () 351-4166 / 861-4166

If a certificate of compliance will not be issued unless repairs or alterations are performed, they will be made by:

Owner _____ Proposed Occupant ☒ Other _____

B. B. Myslis
Applicant's Signature

9106 N Port Wash. Rd. Milwaukee 53217
Applicant's Address

NOTE: A copy of a Certificate of Compliance or Notice of Noncompliance will be given to all persons named above.

For Office Use Only:

No. 4038 Date Received 2/11/97

Amount \$100.00 Receipt 10441

Inspection made 2/17/97

Signature [Signature]

1 ~~Learn~~
2 ~~Now~~ ~~case~~ ~~empty~~ ~~my~~ ~~Phone~~ ~~light~~ ~~Barney~~
3 ~~At~~ ~~CMV~~ ~~Below~~ ~~Just~~ ~~Barney~~
4 ~~ET~~
5 ~~ET~~

6 ~~Space~~ ~~to~~ ~~replace~~ ~~gear~~ ~~splices~~
7 ~~of~~ ~~front~~ ~~gear~~

8 ~~Light~~ ~~Down~~ ~~Barney~~

9 ~~He~~ ~~away~~ ~~forward~~

10 ~~Down~~ ~~spit~~ ~~repair~~
11 ~~Suppose~~ ~~3~~ ~~low~~

INSPECTION DEPARTMENT
VILLAGE OF FOX POINT
7200 N. SANTA MONICA BOULEVARD
MILWAUKEE, WISCONSIN 53217

APPLICATION FOR INSPECTION AND ISSUANCE
OF CERTIFICATE OF COMPLIANCE

(Please type or print clearly)

No. 3388 Date JULY 23, 1993

Address 8401 N. FOXCROFT LN Fox Point, Wisconsin.

Type of Proposed Occupancy SINGLE FAMILY RESIDENCE

Owner of Building THOMAS + VERONICA VAN DALEN

Building Owner's Address:

8401 N. FOXCROFT LN., FOX POINT

Building Owner's Telephone Number (414) 228-6831
area code

Proposed Occupant's Name (if known) _____

Proposed Occupant's Present Address:

Proposed Occupant's Telephone Number ()
area code

If a certificate of compliance will not be issued unless repairs or alterations are performed, they will be made by: _____

Owner X Proposed Occupant _____ Other _____

[Signature]
Applicant's Signature

8401 N. FOXCROFT LN., FOX POINT
Applicant's Address

NOTE: A copy of a Certificate of Compliance or Notice of Noncompliance will be given to all persons named above.

Application and fee received:

rec 32647
\$ 50

Date 7/23/93

Received by cm

Inspection made:

Date 8/13/93

Signature [Signature]

① Sed gms box
② Plate scale box 1050 to 1200

Plumber OTTO W. SPITZ
Drainlayer 11
Address 5231 N. 124TH ST.
Tel. No. 781-6320

No. 4404

Application and Record

Owner THOMAS FLEMING
Address _____
Date 12/3, 1968

To the VILLAGE OF FOX POINT, PLUMBING AND WATER INSPECTION DEPARTMENT: The undersigned hereby make application to do the work of plumbing - drainlaying - consisting of

laying a 4 inch CLAY laying a 1 inch COPPER
drain pipe from Main to Lot line service pipe from Main to Lot line
to Building to Building

at

8401 N. FOXCROFT LANE

Fox Point, Wis.

Address at which work is to be done

PERMITS ISSUED

Kind	No.
Sewer and Plumbing	<u>4555</u>
Water	<u>2367</u>
Street	<u>2136</u>
Meter	<u>2361</u>
Water Usage	<u>2097</u>

Subdivision	Lot	Block
<u>FOX CROFT HIGHLANDS</u>	<u>5</u>	

In the performance of this work the undersigned Plumber or Drain Layer hereby agrees to be bounden by and submit to all statutes, city ordinances, and rules and regulations prescribed by the Village Board for the government of Plumbers and House Drain Layers.

License No. 2741 Otto W. Spitz Plumber

FEES

FIXTURES WITH DRAIN OR WATER CONNECTIONS

No.	No.
Hose Bibs <u>2</u>	Dishwasher <u>1</u>
Bath Tubs <u>1</u>	Wash Basins <u>3</u>
Sump Pump <u>1</u>	Water Closets <u>3</u>
Laundry Tubs <u>1</u>	Showers <u>1</u>
Sanitary Bubblers	Basement Drains <u>1</u>
Sinks <u>1</u>	Garbage Disposal <u>1</u>
Water Heater <u>1</u>	Sprinkling System
Wash Mach. Waste	

Water Usage	\$ <u>56.46</u>
Sanitary Sewer Connection	<u>6.00</u>
Water Connection	<u>5.00</u>
Water Heater <u>BLDG. DRAIN</u>	<u>5.00</u>
Fixtures	<u>12.00</u>
Water Meter <u>9 2 1/2" x 1/2"</u>	<u>57.41</u>
Total	<u>146.87</u>
Deposit to cover street repairs	<u>\$100.00</u>

Earl H. Plank Permit Clerk

A 1 inch copper water service pipe was laid in set to house
Curb box is located _____ feet _____ of _____ feet _____ of _____
See back of building permit card for step box tie in
3/4 inch Brass Water Meter No. 9894447 Date Installed 3/18/69

A 4 inch Clay sanitary sewer connection was made in main (Buff. Conn.)
_____ feet _____ of manhole _____

A _____ inch _____ storm sewer connection was made in _____
_____ feet _____ of manhole _____

Outside Sewer	Report	Inside Sewer	Report	Rough In Plumbing Inspection	Report	Final Inspection	Report
<u>12-16-68</u>	<u>O.K.</u>	<u>12-30-68</u>	<u>O.K.</u>	<u>12-30-68</u>	<u>O.K.</u>	<u>3-28-69</u>	<u>O.K.</u>

Installation Approved 3-28-69 Application Approved 12-3-68, 1968

As Built _____
Earl H. Plank
Water and Plumbing Inspector

REMARKS

DISCREPANCY RECORD

RECEIVED
PAYMENT
DEC 9 1968

Rec # 25920
5530

VILLAGE OF FOX POINT
By W. J. BEONG, Treas.

Owner Thomas Fleming

Plumber Otto W. Spitz

Permit No. 4404 4883

Street 8401 N. 1st Street Lane

848

INSPECTION APPROVAL

Permit 7279

Date 3/26/69

TO DEPT. OF BUILDING INSPECTION
VILLAGE OF FOX POINT

Please be advised that the undersigned has made a Final

Electrical Inspection of the residence of _____

located at 8401 - Foxcroft Lane and hereby approves same.

REMARKS:

Signed Walter J. Kaiser
WALTER J. KAISER
ELECTRICAL INSPECTOR
VILLAGE OF FOX POINT

License No. 133

SHEET 2 — VILLAGE'S COPY

Permit No. 7279Rec # 25976
1-10-69**DEPARTMENT OF ELECTRICAL INSPECTION****Application for Permit for Electrical Installation**

VILLAGE OF FOX POINT

Jan. 8, 1969

TO THE ELECTRICAL INSPECTOR:

Date.....

The undersigned hereby applies for a permit for the execution of electrical installation for light, heat, or power, as hereafter prescribed:

Location 8401 Fox Croft Lane
(Give exact street and number. Do not give corner)Elec. Contractor Meg Electric, Inc. Address 8136 W. Appleton Ave.Builder D. E. Somers & Assoc. Address 516 Rosedale Dr.

Owner..... Address.....

What is occupancy of the building NEW ☒ OLD ☐ Residence

1. Outlets.....	86	each	\$.15	12.90
2. Fixtures.....	26	each10	2.60
3. Fixtures — fluorescent, cold cathode, lumiline, mercury vapor.....	1	each lamp10	.10
4. Audible or visual devices.....	2	per device10	1.00
5. Exhaust and ventilating fans and their control (below 1 H.P.).....	1	each50	.50
6. Built-in electric heaters; bathroom, nursery, etc.....	1	each50	.50
7. Garbage Disposal.....	1	each50	.50
8. Dishwasher.....	1	each50	.50
9. Clothes dryer.....	1	each50	.50
10. Range or other receptacles over 150 volts.....	1	each50	.50
11. Water heater.....	2	each50	1.00
12. Automatic heating equipment — gas, oil, coal.....	2	each	2.00	4.00
13. Automatic water systems.....		each	1.00	
14. Refrigerating, air conditioning, etc., machines.....		each	2.00	
15. Strip lighting, plug in strip, trol-e-duct, etc.....		per ft.03	
16. Dimmers or Time Clocks.....		each50	
17. Vacuum and Inert-Gas tube sign.....		each transformer.....	.50	
18. Incandescent Signs, studded lights.....		per socket05	
19. Arc and mercury lamps, spot and floodlights (mogul base).....		each25	
20. Motors, each horsepower or fraction thereof each motor.....	1	H. P.15	.15
21. Generators, rectifiers, transformers, etc.....		K. W.10	
22. Feeders or subfeeders No. 3 B & S gauge or larger.....		each	1.00	
23. Raceways, wireways, busways, gutters.....		per ft.05	
24. Electric heating devices (other than those listed above).....		first kilowatt50	
25. Service equipment — 0-100 amps. new or overhauling.....	1	per disconnect	1.00	1.00
Service equipment — 100 amps. to 600 amps.....		per disconnect	2.00	
Service equipment — over 600 amps.....		per disconnect	4.00	
26. Temporary service, etc. (3 month period).....	1	each	2.00	2.00
27. Motion picture, stereopticon and x-ray machines, etc.....		each	2.00	
28. Re-inspection after time limit on notice.....		each	2.00	
29. Minimum fee for any permit requiring separate inspection.....		MINIMUM FEE	2.00	
30. Double fee shall be charged for any work started before filing an application for a permit.....		FEES DOUBLE50
31. Final inspection for permit number.....	50	
TOTAL FEES.....				26.25

It is hereby agreed between the undersigned, as owner, his agent or servant and the Village of Fox Point that for and in consideration of the premises and of the permit for the execution of electrical installation, for light, heat or power as above described, to be issued and granted by the Electrical Inspector, that the work thereon will be done in accordance, with the description herein set forth in this statement, and it is further agreed to alter or install same in strict compliance with the Village of Fox Point Elec. Code and to obey any and all lawful orders of the Electrical Inspector of the Village of Fox Point, the Statutes of the State of Wisconsin and the rules and regulations issued by the Industrial Commission of Wisconsin under authority of the State Statutes.

REMARKS: job no. 3652

Date for Inspection	Date Approved	Signature
Roughing in <u>Will notify</u>		<u>Milton E. Gehlke</u> (Supervising Electrician)
Temp.....		Address <u>8136 W. Appleton Ave.</u>
Final.....		City <u>Milwaukee</u>
		Zone <u>53218</u> Telephone <u>463-3550</u>

Make check Payable to Treasurer, Village of Fox Point.

SEWER AND PLUMBING DEPARTMENT

Permit No. 9475 Application No. 9520 Fox Point, WI 8/29/01 20

Permission is hereby given to do the necessary plumbing work on the premises of
described as follows:

Lot Block Subdivision

Located at 8401 N. Fox Point

The above named is permitted to employ _____

License No. _____ for the purpose of laying a _____ inch _____

Sanitary Building Sewer from Main to Curb to Lot line to Premises. Connection to be made in
_____ feet _____ of _____

Laying a _____ inch _____ Building Storm Sewer _____

Fixtures with drain or water connection:

	No.		No.		No.
Hose Bibs		Water Heaters		Water Closets	1
Bath Tubs	1	Wash Mach Waste		Showers	
Sump Pumps		Bidets		Floor Drains	
Laundry Trays		Catch Basins		Food Waste Grinders	
Drinking Fountains		Dishwashers		Sprinkling Systems	
Sinks	1	Wash Basins		Urinals	

as per application made subject to the Rules and Regulations of the Village Board and of Chapter 12 of the Fox Point Village Code.

Building Sewer \$ _____

Building Drain \$ _____

Fixtures \$ 40.00
Rec'd for Permit \$ Receipt #

Plumbing Inspector

2334

Village of Fox Point, Milwaukee County, Wisconsin
Inspector of Buildings Department

Certificate of Electrical Inspection

To Wis. Elec. Power Co.: Relative to

Premises..... 8401 N. Fox Croft *Fox Point*

Owner..... Tom Van Dalen

This is to Certify, that electrical work done under Permit No..... 12374is by this

DEPARTMENT to..... Circle Electricis in conformity with the provisions of the Electrical Code of the Village of Fox Point, Milwaukee County, Wisconsin.

INSTALL:

☐ Service to Temporary Pole ☐ Temporary Service and Meter to Building ☒ Permanent Service to Building ☐ Hot Water Heater Service and Meter ☐ Other.....

Remarks:.....
.....

Dated..... May 15, 19 91

S. J. M. I.
Electrical Inspector, Village of Fox Point.

SEWER AND PLUMBING DEPARTMENT

Permit No. 4555 Application No. 44011 Fox Point, Wis. Dec. 3, 1968

Permission is hereby given to do the necessary draining and plumbing work on the premises of Thomas Fleming described as follows:

Description	Lot	Blk.	Subd.
-------------	-----	------	-------

Fox Craft Highlands 5 and Vac.
part of W. Dean Rd

being No. 2401 on the West side of N. Fox Craft Lane

The above named is permitted to employ OTTO W. Jantz a Licensed

Plumber for the purpose of laying a 4 inch clay Sanitary Sewer drain pipe

from Main to Curb to Lot line to Premises. Connection to be made in main (BUFF. CONN.)

feet of under supervision of Plumbing Inspector

Or of laying a inch Storm Sewer Drain pipe.

Fixtures with drain or water connection

	No.		No.		No.
Bath tubs	<u>1</u>	Sump Pump	<u>1</u>	Wash Basins	<u>3</u>
Laundry tubs	<u>1</u>	Sinks	<u>1</u>	Water Closets	<u>3</u>
Basement drains	<u>1</u>	Showers	<u>1</u>	Hot Water Heater	<u>1</u>
Dishwasher	<u>1</u>	<u>HOUSE BIRS</u>	<u>2</u>	Garbage Disposal	<u>1</u>

as per application made subject to the Rules and Regulations of the Village Board and of Chapter 12 of the Fox Point Village Code.

70 ft trench
Received for Permit \$ 6.00 Dollars

Blk. Drain
Received for Fixtures \$ 12.00 Dollars

\$28.00 O. W. Jantz

PLUMBING INSPECTOR

PERMIT CLERK

WATER PERMIT

Permit No. 2367 Application No. 4404 Fox Point, Wis. Dec. 3, 1968

Permission is hereby given to do the work necessary to supply with water the premises of

Thomas Fleming described as follows:

Description

Lot

Blk.

Fox Crest Highlands

5 and vac. part
of W. Dean Rd.

being No. 8401 on the West side of N. Fox Crest Lane

The above named is permitted to employ Otto W. Spitz a Licensed

Plumber for the purpose of laying a 1 inch copper service pipe from Main to

Curb: a 1 inch copper service pipe from curb to building at same

as per application made subject to the Rules and Regulations of the Village Board and of Ordinance No. 262 of the Village of Fox Point and amendments.

Received for Permit \$ 15.00 Dollars

Received for Fixtures \$ Dollars

Returns must be made on all work done.

Earl H. Plank
WATER INSPECTOR

PERMIT CLERK

E.H. & F
=

INSPECTION APPROVAL

Permit 7279

Date 1/24/69

TO DEPT. OF BUILDING INSPECTION
VILLAGE OF FOX POINT

Please be advised that the undersigned has made a Service
rough in

Electrical Inspection of the residence of D.E. Sommers & Associates

located at 8401-Foxcroft Lane and hereby approves same.

REMARKS:

*Note: Notify Wisconsin Electric Power Co. to connect
service and meter on house*

Signed Walter J. Kaiser
WALTER J. KAISER
ELECTRICAL INSPECTOR
VILLAGE OF FOX POINT

Village of Fox Point, Milwaukee County, Wisconsin

Inspector of Buildings Department

Certificate of Electrical Inspection

To Wis. Elec. Power Co.: Relative to

Premises.....8401 N. Fox Croft Lane.....Fox Point

Owner.....D. E. Sommers & Associates.....

This is to Certify, that electrical work done under Permit No.....7279.....issued by this

DEPARTMENT to.....Meg Electric.....is in conformity with the provisions of the Electrical Code of the Village of Fox Point, Milwaukee County, Wisconsin.

INSTALL:

☐ Service to Temporary Pole ☐ Temporary Service and Meter to Building ☐ Permanent Service to Building ☐ Hot Water Heater Service and Meter ☐ Other.....

Remarks:.....Connect service and meter on house.....

Dated.....January 27....., 1969.....

Electrical Inspector, Village of Fox Point.